

| | | | | | | | |
|--|--|--|--|--|--|--------------------------------|--|
| AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT | | | | 1. CONTRACT ID CODE | PAGE 1 | OF PAGES 3 | |
| 2. AMENDMENT/MODIFICATION NO. <div style="text-align: center;">A001</div> | | 3. EFFECTIVE DATE <div style="text-align: center;">10/19/12</div> | | 4. REQUISITION/PURCHASE REQ. NO. <div style="text-align: center;">AC-12-03732</div> | | 5. PROJECT NO. (If applicable) | |
| 6. ISSUED BY FAA, MIKE MONRONEY AERONAUTICAL CENTER NAS CONTRACTING TEAM AMQ-210 P O BOX 25082 OKLAHOMA CITY OK 73125-4929 | | | | 7. ADMINISTERED BY (If other than Item 6) FOR MORE INFORMATION CONTACT: Name: Lori Lemons Telephone No. (405) 954-5487 | | | |
| 8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) All Offerors | | | | <input checked="" type="checkbox"/> | 9A. AMENDMENT OF SOLICITATION NO. DTFAAC-12-R-13732 | | |
| | | | | <input type="checkbox"/> | 9B. DATED (SEE ITEM 11) 09/17/12 | | |
| *TO BE COMPLETED BY VENDOR IF NOT COMPLETE CODE | | | | <input type="checkbox"/> | 10A. MODIFICATION OF CONTRACT/ORDER NO. | | |
| | | | | <input type="checkbox"/> | 10B. DATED (SEE ITEM 13) | | |
| FACILITY CODE | | | | | | | |

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer is ☐ extended ☒ is not extended.

NOTE: If offers are hand carried, additional time should be allowed to access the depository facility due to heightened security requirements. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Item 8 and 15, and returning 1 copies of the amendment; (b) acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. **FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.** If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hours and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

☐ A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT/ORDER NO. IN ITEM 10A.

☐ B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14.

☐ C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:

☐ D. OTHER (Specify type of modification and authority)

E. **IMPORTANT:** Contractor ☐ is not, ☒ is required to sign this document and return **1** copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

The Request for Offer referenced in Item 9A above for waterproofing of the ATCT in Sanford, FL is amended as follows:

- 1. Page 26 of the SIR/RFO is replaced by Page 26R to add Addendum Two as an attachment.**
- 2. Addendum Two is added as an attachment to provide clarification and answers to questions from the site visit.**
- 3. Time and date for receipt of proposals is unchanged.**

Reference Item 11 above. Acknowledge receipt of this amendment to:
 FAA Bid & Proposal Officer (AMQ-100)
 Room 313, Multi-Purpose Building
 6500 South MacArthur Boulevard (P.O. Box 25082, Zip 73125-4933)
 Oklahoma City, OK 73169-4933

| | | | |
|---|--|---|--|
| 15A. NAME AND TITLE OF SIGNER (Type or print) | | 16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) | |
| 15B. CONTRACTOR/OFFEROR BY _____ (Signature of person authorized to sign) | | 16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer) | |
| 15C. DATE SIGNED | | 16C. DATE SIGNED | |

PART III - SECTION J
LIST OF ATTACHMENTS

| <u>ATTACHMENT</u> | <u>TITLE</u> | <u>DATE</u> | <u>NO. OF PAGES</u> |
|-------------------|---|-------------|---------------------|
| 1 | Specification No.FAA-SO-42354 | 01/10/12 | 74 |
| 2 | Drawing No. SO-D-102218-T-03 | Various | 5 |
| 3 | Addendum One | 06/28/12 | 1 |
| 4 | Davis Bacon Wage Rate Decision, General Decision No. FL120038 Construction Type: Building | 07/06/12 | 5 |
| 5 | Standard Form 25, Performance Bond | 05/96 | 2 |
| 6 | Standard Form 25A, Payment Bond | 10/98 | 2 |
| 7 | Contractor's Release | 05/05 | 1 |
| 8 | Addendum Two | 10/18/12 | 1 |

DATE: October 19, 2012

SUBJECT: Addendum No. One to the Specifications and Drawings for the waterproofing of the ATCT in Sanford, FL.

This Addendum modifies and takes precedence over the original Specifications and Drawings and forms a part of the contract documents.

Add the following

Division 1, 1 A.2 Scope of work , page 4 , Cab Roof change paragraph 3, the following section that read pvc roof system with felt back to read pvc roof system with .5 inch with dense deck. (This Is only for the cab roof).

Division 1, 1 A.2 Scope of work, Catwalk and interior work, paragraph 2, Delete Tower shaft work paragraph on page 3.

Division 1, 1 A.2 Scope of work, Cab Roof: Add the enclose extra work Item: 8. Install 1" inch insulation to the four sides of the two a-c unit curbs before flashing.

Division 1, 1 A.2 Scope of work, Cab Roof: Item 3: Remove the requirement for felt back for the cab roof membrane and add the requirement to install 1/2" - 4' x 4' dens deck 6 fasteners per board over the entire cab roof. On page 4.

Division 1, 1 A.2 Scope of work, Cab Roof: Add the enclose extra work Item 9: Replace a 10' x 10' cab roof insulation area to match existing thickness. Six fasteners per board. The area of replacement will be identified by the Eng. before the work start. On page 4. (The existing roof involve a cover board, taper insulation 1/4" per feet slope roof slope the 4.5" highest thickness and the bottom layer is 5" ISO this information is for bidding purposes).

Division 1, 1 A.2 Scope of work, Option: Remove the option paragraph from the scope of work on page 4.

Division 7, Single ply Roof System: 7 A.1 Scope of work: replace the first sentence with: Replace insulation in designated area of the base building and cab areas. (See page 10)

Division 7, Single ply Roof System: 7 B.13 Field Quality Control: Add the following the contractor is required to have the manufacturer inspector the first day of installation of membrane, at the middle, and at the end of the project. The name and phone of the rep shall be submitted with the submittals. Tech rep from the manufacturer is required to give a copy of their inspection report to the roof contractor, the general contractor and the government rep on site. (see page 24)

Division 7, Single ply Roof System : 7 B.2 THIRD PARAGRAPH Acceptable substitution: Change 50 mils to 90 Mils.(See page 12).

7B.2 THIRD PARAGRAPH Acceptable substitution: Change 50 mils to 90 Mils.

7B.13 at page 24. Add the following the contractor is required to have the manufacturer inspector the first day of installation of membrane at the middle of the project and at the end of the project. The name and phone of the rep shall be submitted with the submittals.

Clarifications

Q: Spec section 07180 Liquid Applied Pedestrian Traffic Waterproofing states scope of work and description of system to be Siplast Terapro Waterproofing System. Will the equivalent system by Soprema, called Alsan RS be acceptable?

A: Yes